

\*\* OCR, Feeders and Subs are included. Fuses, transformers and individuals are not. \*\*

**JUNE 2021**

**06/02/2021 –**

9:15am Newbern – clear/calm; tree contractor got in line, blown line fuse; off 1hr 40mins

11:34am Staunton – clear/calm; blown line fuse, no cause found, off 3hrs 25mins

**06/05/2021 – 12:47pm**

Bunker Hill – OCR; birds on the line; off 3hrs 45mins

**06/12/2021 –**

5:08pm Newbern – clear/calm; bad U.G. primary conductor; off 3hrs. 40mins

7:31pm Butler – tree hit line slapping them together; off 2hrs 27mins

**06/13/2021 – 6:52pm**

Newbern – clear; calm; trees in line, off 2 ½ hrs.

**06/16/2021 –**

11:30am - Newbern - #740 ABC-phases; broken 3-phase pole; off 2 ½hrs

7:11pm Nutwood – clear/calm; tree thru line, off 2hrs 24mins

**06/19/2021 –**

8:35am Witt – storm; lines burnt down & 7 transformers blown due to lightning; off 3hrs.

3:43pm Nutwood – storm; trees thru line; flooded roads; off 8 ½hrs.

**06/22/2021 – 9:08am**

Newbern – clear/calm; tree contractor put limb thru line, off 1 ½hrs.

**06/23/2021 – 8:27pm –**

Brighton – clear/calm; vehicle hit pole; off 1hr 22mins

**06/25/2021 –**

1:49am Nutwood – rain; lightning strike; tree in line; off 2hrs 11mins

1:51am Jerseyville – rain; trees thru line; off 1hr. 38mins

7:28am Bunker Hill – rain; OCR #870 opened; tree on line, off 1hr.

10:47am Jerseyville – rain; OCR #718 open; no cause found; off 1 ½hrs.

**06/26/2021 – 8:27am**

Nutwood – calm/clear; tree in line, off 2hrs

**06/28/2021 –**

10:42am Rinaker – clear/calm; tree thru line in private, off 1 ½ hrs

2:27pm Bunker Hill – rain/lightning; ABC-Phases; Power Supplier/transmission tap; off 42mins

2:28pm Brighton – lightning; ABC- Phases; Substation, off 43mins, OCR