\*\* OCR, Feeders and Subs are included. Fuses, transformers and individuals are not. \*\*

# **AUGUST 2021**

# 08/08/2021 -

4:16PM - Nutwood – storms/ severe lightning; ABC-phase's - trees took lines down, off 9hrs.

4:27PM - Jerseyville – storms/lightning; trees in line, off 2hrs 40mins

# 08/12/2021 - 4:01PM

Taylor Springs – rain; major storm – broken pole, off 4 ½ hrs.

### 08/18/2021 - 3:36AM

Taylor Springs – clear/calm; breaker # 807 open all 3-phases due to broken neutral & tree in line, off 5hrs.

### 08/29/2021 - 3:29AM

Womac – clear/calm; primary u.g. conductor, off 7hrs.