

Outage Stats for the Month of May 2026

Reporting Outages with 10+ Meters Off at One Time

Time Off	Cause Description	Substation	Feeder	Meters Out
05/03/2026 15:30:10	LIGHTNING	08-Rinaker Sub	1	22
05/05/2026 18:05:35	TREES	05-Jerseyville Sub	6	47
05/05/2026 19:52:00	VEHICLE	05-Jerseyville Sub	6	23
05/05/2026 23:42:48	VEHICLE	01-Brighton Sub	1	16
05/06/2026 04:42:23	VEHICLE	01-Brighton Sub	1	16
05/07/2026 05:59:47	MAINTENANCE	11-Womac Sub	99	787
05/07/2026 08:00:00	CONSTRUCTION	04-Witt Sub	7	15
05/07/2026 11:00:00	MAINTENANCE	14-Hornsby Sub	99	183
05/07/2026 23:21:49	TREES	12-Newbern Sub	1	70
05/08/2026 04:08:24	ANIMAL	02-Bunker Hill Sub	99	908
05/08/2026 12:09:59	EQUIPMENT	02-Bunker Hill Sub	99	907
05/08/2026 12:11:51	EQUIPMENT	02-Bunker Hill Sub	1	155
05/08/2026 12:14:25	EQUIPMENT	02-Bunker Hill Sub	5	222
05/08/2026 12:14:26	EQUIPMENT	02-Bunker Hill Sub	5	78
05/08/2026 12:14:52	EQUIPMENT	02-Bunker Hill Sub	5	73
05/08/2026 12:14:53	EQUIPMENT	02-Bunker Hill Sub	5	10
05/08/2026 12:15:12	EQUIPMENT	02-Bunker Hill Sub	5	24
05/10/2026 20:42:06	TREES	10-Taylor Springs Sub	3	187
05/12/2026 06:00:00	MAINTENANCE	09-Staunton Sub	99	635
05/12/2026 11:00:00	MAINTENANCE	01-Brighton Sub	99	1,748
05/12/2026 15:00:00	MAINTENANCE	08-Rinaker Sub	99	928
05/15/2026 10:00:00	CONSTRUCTION	04-Witt Sub	7	15
05/15/2026 15:58:41	VEHICLE	08-Rinaker Sub	7	11
05/16/2026 10:37:18	LIGHTNING	01-Brighton Sub	1	56
05/16/2026 14:24:36	LIGHTNING	02-Bunker Hill Sub	5	19
05/17/2026 17:10:36	TREES	11-Womac Sub	1	82
05/18/2026 10:54:35	UNKNOWN	05-Jerseyville Sub	6	59
05/18/2026 11:42:06	CONDUCTOR	13-Honey Bend Sub	7	12
05/18/2026 15:32:38	TREES	06-Nutwood Sub	1	33
05/20/2026 09:23:37	UNKNOWN	01-Brighton Sub	1	10
05/21/2026 04:19:50	TREES	10-Taylor Springs Sub	3	296
05/21/2026 09:14:30	ANIMAL	08-Rinaker Sub	3	25
05/22/2026 12:10:50	MAINTENANCE	07-Palmyra Sub	1	21
05/24/2026 10:46:33	UNKNOWN	01-Brighton Sub	3	11
05/27/2026 07:47:46	EQUIPMENT	01-Brighton Sub	7	21
05/27/2026 11:14:32	CONNECTIONS	06-Nutwood Sub	1	33