\*\* OCR, Feeders and Subs are included. Fuses, transformers and individuals are not. \*\*

## **MAY 2022**

05/02/2022

Bunker Hill - broken pole OCR #938 all 3-phases. Off 4hrs

05/04/2022

Nutwood – high winds, broken strands, off 40min.

05/05/2022

Nutwood - rain, tree thru line, line down, off 3 1/2 hrs.

Jerseyville - OCR tripped, patrolled line, no cause found, off 2hrs. 40mins

05/08/2022

Staunton - OCR tripped, patrolled line, no cause found, off 2hrs. 40mins

05/09/2022

Rinaker - wind; Breaker #810, line down on Rt. 108 - tree went through the line, off 3 1/2hrs

Jerseyville – wind; tree gone thru the line, off 3hrs. 22mins

Staunton – OCR #916, Tripped, no cause found, off 2hrs

05/10/2022

Staunton – OCR #916, tripped, no cause found, off 2 hrs.

Jerseyville - broken stinger wire, off 1hr.

05/14/2022

Staunton – birds, OCR tripped, off 1 ½ hrs.

Staunton – broken pole, farm machinery; off 3 ½ hours

05/16/2022

Womac – farm machinery hit anchor and knocked pole down, off 5hrs

05/17/2022

Staunton - OCR #619 tripped, no cause found, off 1hr

Palmyra – farm machinery, clipped guy wire & broke pole, off 4hrs

05/18/2022

Nutwood – tree thru line, took out phase, neutral and U.G, off 4hrs

05/19/22

Staunton – broken 3-phase pole, off 1hr

05/21/2022

Butler – storm, lightning, broken connector, off 1hr.

Taylor Springs - bad switch, off 2hrs.

05/23/2022

Nutwood - bad transformer, off 3hrs.

05/24/2022

Jerseyville - line down across rd., off 2hrs

05/25/2022

Womac - lines were twisted together, tripped OCR, off 1hr

05/28/2022

Nutwood – blown line fuse, OCR tripped – no cause found, off 4hrs

05/29/2022

Staunton – 3-PHASE, broken pole top, off 4hrs

05/30/2022

Brighton - farm equipment, (2) broken poles, off