

** OCR, Feeders and Subs are included. Fuses, transformers and individuals are not. **

JUNE 2020

06/02/2020 –

1:56AM - Jerseyville – Ocr tripped, patrolled line, no cause found, off 2hrs. 38mins

12:19PM - Jerseyville/Brighton – farmer hit switch pole, lines & pole down, took (2) subs off, off 1 ½ hrs.

06/22/2020 –

4:51PM - Nutwood – tree thru line, off 2hrs.

11:57PM - Brighton – car hit guy wire broke anchor, off 1hr. 13mins

06/24/2020 – 1:20PM

Jerseyville – c/o (2) poles WO#2006807, off 43mins.

06/25/2020 – 12:31PM

Rinaker – planned outage, men working on underground, WO#1911800LC, off 1hr

06/28/2020 – 9:25PM

Newbern – two high side fuses blew in sub, off 2 ½ hrs.

06/29/2020 – 11:22AM

Bunker Hill – planned outage, crews changed out underground transformer, off 1 ½ hrs